

# Certificate

Registration No.: PV 50180992

Page 1

Report No.: 12606594 003

**License Holder:**  
**Silex Solar Pty Ltd.**  
2 Australia Ave  
Sydney Olympic Park  
NSW 2127, Australia

**Product:**  
PV Module  
Type: SLXxxx

xxx = 165, 170, 175, 180, 185 and 190

**Manufacturing Plant:**  
**Silex Solar Pty Ltd.**  
2 Australia Ave  
Sydney Olympic Park  
NSW 2127, Australia

## Basis:

- IEC 61215:2005**  
**EN 61215:2005**  
"Crystalline silicon terrestrial photovoltaic (PV) modules - Design qualification and type approval"
- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- **Periodic inspection**
- **Qualified, IEC 61215**
- **Safety tested, IEC 61730**

## Remarks:

The details of the factory inspection are documented in report no. 12607214.

## Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.  
The certificate has a validity of 5 years counting from date of issue.



Certification body

  
Dipl.-Ing. W. Heritschke

Yokohama, 17 May 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan

# Certificate

Registration No.: PV 50180993

Page 1

Report No.: 12606594 004

**License Holder:**  
**Silex Solar Pty Ltd.**  
2 Australia Ave  
Sydney Olympic Park  
NSW 2127, Australia

**Product:**  
PV Module  
Type: SLXxxx

xxx = 165, 170, 175, 180, 185 and 190

**Manufacturing Plant:**  
**Silex Solar Pty Ltd.**  
2 Australia Ave  
Sydney Olympic Park  
NSW 2127, Australia

**Basis:**

- IEC 61730-1:2004  
IEC 61730-2:2004  
EN 61730-1:2007  
EN 61730-2:2007  
"Photovoltaic (PV) module safety qualification"

- Factory Inspection**  
To document the consistent quality of the product factory inspections are performed periodically.



- Periodic inspection
- Qualified, IEC 61215
- Safety tested, IEC 61730

**Remarks:**

- IEC EN 61730 consists of part 1 ( Requirements for construction) and part 2 (Requirements for testing).
- The above listed PV modules fulfil the requirements of Application Class A (Safety Class II ). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to 1000 VDC.
- The fire test (IEC 61730-2 / MST 23) was not performed.
- The details of the factory inspection are documented in report no. 12607214.

**Conditions:**

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.  
The certificate has a validity of 5 years counting from date of issue.



Certification body

  
Dipl.-Ing. W. Herlitschke

Yokohama, 17 May 2010

TÜV Rheinland Japan Ltd. – Yokohama 222-0033, Japan